

UAB „SIVENTA“
 Ragainės g. 100, 78109 Šiauliai

SCOPE OF ACCREDITATION

Materials or products tested	Component, parameter or characteristic to be tested	Reference number of the document specifying test methods, clause	Techniques, methods and/or equipment used
Fans and air handling equipment	Fan pressure, fan static pressure Air mass and volume flow Fan power input Fan efficiency, fan static efficiency	LST EN ISO 5801:2018 LST EN ISO 5801:2018/A1:2025 except ch. 8.6, 9.5; annex A.5, A.6	Fan performance testing using standardized airways Pressure difference method. Air flow measurement with pressure differential devices. Electrical input power determination by wattmeter method. Efficiency calculation
Residential ventilation units	External and internal leakage Carry-over of exhaust air to the supply air	LST EN 13141-7:2021+A1:2026 ch. 7.2.1.2, 7.2.1.3	Pressure difference test method. Tracer gas test method
	Air flow/pressure characteristic Electric power input Specific power	LST EN 13141-7:2021+A1:2026 ch. 7.2.2	Fan performance testing using standardized airways Pressure difference method Air flow measurement with pressure differential devices Electrical input power determination by wattmeter method Efficiency calculation

Materials or products tested	Component, parameter or characteristic to be tested	Reference number of the document specifying test methods, clause	Techniques, methods and/or equipment used
	Temperature and humidity ratios	LST EN 13141-7:2021+A1:2026 ch. 7.3 except 7.3.7	Temperature and relative humidity measurement method
	Sound power level measurement A-weighted sound power level Sound power levels 1/1 and 1/3 octave bands (31.5 – 10000) Hz	LST EN 13141-7:2021+A1:2026 ch. 7.4.2	Sound pressure level measurement. An essentially free field over a reflecting plane
All types of noise source (max. dimensions a×b×h: 4m×4m×3,5 m)	Sound power level measurement A-weighted sound power level Sound power levels in 1/1 and 1/3 octave bands (31.5 – 10000) Hz	LST EN ISO 3744:2011	Sound pressure level measurement An essentially free field over a reflecting plane
Residential ventilation units (duct diameter from 100 to 500 mm)	Sound power level measurement A-weighted sound power level Sound power levels in 1/1 and 1/3 octave bands (31.5 – 10000) Hz	LST EN 13141-7:2021+A1:2026 ch. 7.4.3	Determination of sound power radiated into a duct by fans and other air moving devices
Air handling units, recuperators, heat recovery devices	External leakage Static internal leakage	LST EN 308:2022 ch. 6.1.2.1, 6.1.2.2	Pressure difference test method.
	Efficiency test	LST EN 308:2022 ch. 6.1.5	Temperature and relative humidity measurement method
	Pressure drop test	LST EN 308:2022 ch. 6.1.3	Pressure difference method

Materials or products tested	Component, parameter or characteristic to be tested	Reference number of the document specifying test methods, clause	Techniques, methods and/or equipment used
Air handling units	External casing air leakage	LST EN 1886:2025 ch. 6	Pressure difference method
	Filter bypass leakage	LST EN 1886:2025 ch. 7	Pressure difference method
	Acoustic insulation of casing Sound power levels in 1/1 and 1/3 octave bands (31.5 – 10000) Hz	LST EN 1886:2025 ch. 9	Sound pressure level measurement. An essentially free field over a reflecting plane
Ducted silencers and air terminal units	Insertion loss Sound power levels in 1/1 and 1/3 octave bands (31.5 – 10000) Hz	LST EN ISO 7235:2010 ch. 6.2	Sound pressure level measurement. Sound pressure level difference method
Ducted silencers and air terminal units	Total pressure loss Total pressure loss coefficient	LST EN ISO 7235:2010 ch. 6.5	Pressure level measurement. Pressure difference method

Director


 (signature)

Modestas Šimkus
 (name, surname)

